

## CERTIFICATE OF ANALYSIS

<b>MATERIAL.</b>	CALCIUM HYPOCHLORITE. <b>PURICHLOR</b>
<b>MATERIAL CODE.</b>	CALCIUM HYPOCHLORITE – 65% IN GRANULAR FORM.
<b>MATERIAL DELIVERY DATE.</b>	6-FEB-2018
<b>DATE OF MANUFACTURING.</b>	<b>5-FEB-2018</b> <b>EXPIRY 24 MONTHS FROM MFG</b>
<b>TAMPER-EVIDENT SEAL IDENTIFICATION.</b>	SEAL PROVIDED.
<b>QUANTITY.</b>	15.840MT      (352 NO'S HDPE DRUMS OF EACH 045 GKS. ONLY.)
<b>TRUCK. NO.</b>	AP 16U 2418 OF M/S. THIRUPATI TRANSPORT CORP
<b>SL. NO'S OF DRUMS.</b>	Serial Nos.  <b>1700000278241 TILL 300 (60 DRUMS)</b> <b>1700000278581 TILL 610 (30 DRUMS)</b> <b>1700000112201 TILL 300 (100 DRUMS)</b> <b>1700000656601 TILL 762 (162 DRUMS)</b>

### CERTIFICATE OF COMPLIANCE AND ANALYSIS.:

THE CALCIUM HYPOCHLORITE DESCRIBED ABOVE COMPLIES WITH ALL THE APPLICABLE LOCAL LEGAL REQUIREMENTS / SPECIFICATIONS AS STATED. PREVENTS FORM CORRSION AND SCALING EFFECTIVELY.

IN ADDITION, THE CALCIUM HYPOCHLORITE HAVE BEEN SAMPLED, TESTED AND FOUND TO MEET THE FOLLOWING MINIMUM SPECIFICATIONS.

TEST PARAMETERS	SPECIFICATIONS	TEST RESULTS
AVAILABLE CHLORINE.	65% MIN.	66.60 %.
STABILITY, LOSS OF CHLORINE ON THE BASIS OF INTIAL AVAILABLE CHLORINE.	10% MAX.	08.20 %.
MOISTURE.	10% MAX.	07.80 %.

DATE: 6-FEB-2018

  
 AUTHORIZED SIGNATORY.



**ANISO9001&14001CERTIFIEDCOMPANY**

Regd.Office&Factory : Gondiparla, Kumool – 518 004 (A.P). India.